



COMMISSIONING REQUEST FORM

Please be aware the boiler must be commissioned within 3 months of the installation date to qualify for the full warranty.

SITE DETAILS

Site contact name

Hemant patel

Site name

Woodlands

Site contact number 1

07771634166

Site contact number 2

07983355509

Site address

4 the woodlands Off old
Croftâ€™s bank Urmston
M41 7AA

Site Postcode

M41 7aa

BOILER 1

Boiler model

Heat 2

Output

55kW

Full serial number

Zu20863400008794

Date code

29/08/19

Installation date

2-Nov-20

Purchase date

9-Sep-19

Merchant purchased from

Quirks Jc 55 Waverley road

Branch

Sale

Is a Keston 28mm System Filter fitted

Yes

INSTALLER DETAILS

Contact name

Stuart glass

Contact number

07545878123

Company name

Betta heating

Email address

info@betta-heating.co.uk

Company Gas Safe Registration

205081

Company address

Betta heating ltd 96 chapel
lane Winslow Sk9 5jh

Company Postcode

Sk95jh

APPOINTMENT DETAILS

Requested visit date

15/12/2020

Is a Site Induction necessary?

No

Do our engineers require CSCS cards?

No

Are Risk Assessment / Method Statements required?

No

Please note the system must be cold and have sufficient heat load so all boilers can be fired full rate

REPORTS

Please provide at least 2 email addresses for the report and warranty certificate (where applicable) upon completion of a successful commissioning

Email address 1

patidarltd@gmail.com

Email address 2

nisastretford@hotmail.co.uk

Are you happy to receive information alongside this report detailing our service & care packages?

Yes

INSTALLATION DETAILS

All of the below must be completed for us to carry out the commissioning.

Please give details of any special instructions in the box provided at the bottom.

Should we be unable to carry out the work, we reserve the right to make a charge for the full cost of the visit.

Any calls cancelled without 24 hours notice may be charged at the full commissioning cost.

Is adequate purpose built ventilation installed?	Yes
---	-----

What percentage has this been calculated at?	75%
---	-----

Is ventilation mechanical or natural?	Mechanical
--	------------

Does the flue comply with BS:6644, BS:5440, IGE UP/10 & CE Approved?	Yes
---	-----

How is the flue installed?	Vertically
-----------------------------------	------------

Has the electrical supply been connected with option to isolate?	Yes
---	-----

Has water been connected, boiler filled and air removed?	Yes
Has the gas been connected and purged?	Yes
Have external controls been commissioned & operational?	Yes
Is a permanent light available in the boiler room?	Yes
Is the boiler showing any faults?	No
Is the boiler showing any faults?	No
Is the boiler fully accessible?	Yes
Is adequate onsite parking available?	Yes
Has the system been cleansed before installation?	Yes
Has the system been dosed since installation?	Yes

Additional site information

I have answered questions best of my knowledge as I am the customer and not technically minded.

COST BREAKDOWN

Commissioning costs	
Heat 2	£0.00
Total Commissioning Costs	£0.00
Site induction costs	
20 minute induction	£0.00
Additional	£0.00
Total Induction Costs	£0.00
Total Costs	£0.00

CONFIRMATION BY

Full name

Hemant patel

Email address

patidarltd@gmail.com

I confirm that I have completed this form as accurately as possible and that any incorrect information provided may lead to delays and/or return visits, which may be chargeable. I am aware that my requested commissioning date may not be

available.

Confirmation of your visit date will be supplied within 2 working days

I confirm I have read the Terms & Conditions of use for keston.co.uk. As a data controller, Keston Boilers Ltd take the protection of your personal data seriously. To view our Privacy Policy, please click here.