



COMMISSIONING REQUEST FORM

Please be aware the boiler must be commissioned within 3 months of the installation date to qualify for the full warranty.

SITE DETAILS

Site contact name

clark

Site name

highmead birchwood grove
road

Site contact number 1

07778267116

Site contact number 2

07739281487

Site address

highmead birchwood grove
road burgess hill sussex
RH15 0DL

Site Postcode

Rh15 0DL

BOILER 1

Boiler model

Heat

Output

55kW

Full serial number

XU20863400008266

Date code

190222

Installation date

20-Feb-20

Purchase date

11-Feb-20

Merchant purchased from

KDS PEACEHAVEN

Branch

PEACEHAVEN

Installed options

Outside sensor kit

Is a Keston 28mm System Filter fitted

No

INSTALLER DETAILS

Contact name

PAUL CREED

Contact number

07778267116

Company name

PAUL CREED

Email address

paul-creed@hotmail.com

Company Gas Safe Registration

192054

Company address

12 victor close seaford east
sussex

Company Postcode

BN25 2JQ

APPOINTMENT DETAILS

Requested visit date

02/03/2020

Is a Site Induction necessary?

No

**Do our engineers require
CSCS cards?**

No

**Are Risk Assessment /
Method Statements
required?**

No

Please note the system must be cold and have sufficient heat load so all boilers can be fired full rate

REPORTS

Please provide at least 2 email addresses for the report and warranty certificate (where applicable) upon completion of a successful commissioning

Email address 1

Email address 2

PAUL-
CREED@HOTMAIL.COM

sharacc27@yahoo.co.uk

Are you happy to receive information alongside this report detailing our service & care packages?

No

INSTALLATION DETAILS

All of the below must be completed for us to carry out the commissioning.

Please give details of any special instructions in the box provided at the bottom.

Should we be unable to carry out the work, we reserve the right to make a charge for the full cost of the visit.

Any calls cancelled without 24 hours notice may be charged at the full commissioning cost.

Is adequate purpose built ventilation installed?	No
---	----

What percentage has this been calculated at?	100%
---	------

Is ventilation mechanical or natural?	Natural
--	---------

Does the flue comply with BS:6644, BS:5440, IGE UP/10 &	Yes
--	-----

CE Approved?

How is the flue installed?	Horizontally
-----------------------------------	--------------

Has the electrical supply been connected with option to isolate?	Yes
---	-----

Has water been connected, boiler filled and air removed?	Yes
---	-----

Has the gas been connected and purged?	Yes
---	-----

Have external controls been commissioned & operational?	Yes
--	-----

Is a permanent light available in the boiler room?	Yes
---	-----

Is the boiler showing any faults?	No
--	----

Is the boiler showing any faults?	No
--	----

Is the boiler fully accessible?	Yes
--	-----

Is adequate onsite parking available?	Yes
--	-----

Has the system been cleansed before installation?	Yes
--	-----

Has the system been dosed since installation?	Yes
--	-----

Additional site information

n/a this commissioning is

requested as free option only
please advise if not free

COST BREAKDOWN

Commissioning costs	
Heat	£125.00
Total Commissioning Costs	£125.00
Site induction costs	
20 minute induction	£0.00
Additional	£0.00
Total Induction Costs	£0.00
Total Costs	£125.00

CONFIRMATION BY

Full name

paul creed

Email address

paul-creed@hotmail.com

I confirm that I have completed this form as accurately as possible and that any incorrect information provided may lead to delays and/or return visits, which may be chargeable. I am aware that my requested commissioning date may not be available.

Confirmation of your visit date will be supplied within 2 working days

I confirm I have read the Terms & Conditions of use for keston.co.uk. As a data controller, Keston Boilers Ltd take the protection of your personal data seriously. To view our Privacy Policy, please click here.